



# **CERTIFICATE**

## **FOR EUROPEAN PRODUCT SAFETY**

Reference No. SE-S-2500415

### Halogen free house wiring cable

**Type designation:** EXQ

**Certificate holder:** Xaver Bechtold GmbH  
Unterdorf 101  
DE-78628 Rottweil  
GERMANY

**The product complies with the standard(s):** SS 424 02 19-5:2017

**Date of expiry:** 09 May, 2030

Additional information in Appendix

**Certification Body:** Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

**Signed:**  **Date:** 09 May, 2025

Anneli Averland Johansson

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. This certificate is not issued under accreditation, by a non-approved body.



## APPENDIX:

Reference No. SE-S-2500415

### Technical Data:

Type designation	EXQ
Rated voltage (V)	300/500 V
Number of conductors	2-5
Conductor area	1,5-2,5 mm <sup>2</sup>
Trademark	XBK
Test Report	2500531STO-001
Product information	XLPE-insulated, HFFR-sheathed house wiring cable. Typ 2. Fire code C <sub>ca</sub> S <sub>2</sub> d <sub>2a1</sub>

### Manufacturing Sites:

Xaver Bechtold GmbH  
Unterdorf 101  
DE-78628 Rottweil  
GERMANY

### Certification Body:

Intertek Semko AB, Product Certification

**Place:** Kista - Stockholm

### Signed:



Anneli Averland Johansson

**Date:** 09 May, 2025